

October 11, 2017

**ADDENDUM #2**

Ref: **Mirando City Elevated Water Storage Tank (TxCDBG #7216115)**

Bidders are advised of the following changes and/or clarifications to the plans and specifications:

**DIVISION D - Technical Specifications:**

**ELEVATED STORAGE TANK:**

**APPURTENANCES & ACCESSORIES,**

Roof Hatches (Page D-17)

DELETE: the first sentence of second paragraph.

ADD/REPLACE: "The second hatch will be at least 30 inches in diameter and flanged with a removable cover, so constructed that an exhaust fan may be connected for ventilation during painting operations."

Tank Vent (Page D-17)

ADD: "The roof vent screen shall be fabricated of corrosion-resistant material and shall be 16-wire mesh or finer."

**BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 2 ON THEIR BID PROPOSAL TO HAVE THEIR BIDS RECOGNIZED.**

If you have any questions or concerns contact our office at (956) 724-3097.

Recommended by:

  
Wayne Nance, PE  
Porras Nance Engineering

